

## Installation of the Series 2000PVPV MEGALUG® as a Bell Protection System for large diameter piping in sizes 14-inch through 36-inch

1. Place the 2000PV Series over the spigot end of the PVC pipe with the Mechanical Joint (MJ) lip of the 2000PV Series facing away from the pipe bell. Position the back of the 2000PV Series until it touches the pipe manufacturer's reference mark and remains visible. (See Photos A&B)

Photo A



Photo B



2. Set the wedges on the 2000PV Series by alternating in a star pattern until all torque limiting nuts are removed. Place the gasket against the 2000PV Series and on top of the manufacturer's reference mark.

(See Photos C&D)

Photo C



Photo D



3. Place the spigot end of pipe into the mating bell and push the pipe into the bell until the gasket meets the face of the bell. (See photos E&F)

Photo E



Photo F

